

LIGHT FIXTURE SCHEDULE

MARK	MANUFACTURER SERIES NUMBER	MOUNTING	LAMPS		VOLTS	WATTS	DESCRIPTION
			NO.	TYPE			
A	LITHONIA LIGHTING SERIES # 2ALL	RECESSED	-	6000 LUMEN 3500K LED	120V/277V	47W	2' x 4' ARCHITECTURAL TROFFER WITH A LUMINOUS DIFFUSER COMBINED WITH CONCAVE REFRACTOR, HINGED DOORFRAME, ELECTRONIC 0-10V DIMMING DRIVER.
B	LITHONIA LIGHTING SERIES # 2ALL	RECESSED	-	7200 LUMEN 3500K LED	120V/277V	68W	2' x 4' ARCHITECTURAL TROFFER WITH A LUMINOUS DIFFUSER COMBINED WITH CONCAVE REFRACTOR, HINGED DOORFRAME, ELECTRONIC 0-10V DIMMING DRIVER.
C	LITHONIA LIGHTING SERIES # 2ALL	RECESSED	-	4000 LUMEN 3500K LED	120V/277V	35W	2' x 2' ARCHITECTURAL TROFFER WITH A LUMINOUS DIFFUSER COMBINED WITH CONCAVE REFRACTOR, HINGED DOORFRAME, ELECTRONIC 0-10V DIMMING DRIVER.
D	GOTHAM LIGHTING SERIES # EVO	RECESSED	-	2500 LUMEN 3500K LED	120V/277V	30W	6" NOMINAL OPEN DOWNLIGHT, CLEAR TRIM, SELF-FLANGED, SEMI-SPECULAR FINISH, MEDIUM WIDE (1.0 S/MH) DISTRIBUTION, ELECTRONIC 0-10V DIMMING DRIVER.
E	HEALTHCARE LTG SERIES # HNL610	WALL MOUNTED	-	3000K LED	120V/277V	2W	RECESSED PATIENT ROOM NIGHT LIGHT WITH LOUVER FACEPLATE, FLAT WHITE FINISH, ELECTRONIC DRIVER.
F	GOTHAM LIGHTING SERIES # EVO-DFRAMF	RECESSED	-	2000 LUMEN 3500K LED	120V/277V	24W	6" NOMINAL NON-CONDUCTIVE LENSED DOWNLIGHT WITH REGRESSED DOOR FRAME, ANTI-MICROBIAL FINISH, ELECTRONIC 0-10V DIMMING DRIVER, IP65 RATED.
G	LUMIDESIGN, AMBER	WALL MOUNTED	-	3000K LED 90 CRI	120V	24W	LIGHTED MIRROR, 22"x40"x1.75", SANDBLASTED MIRROR FINISH. 12-14 WEEK LEAD TIME.
H	Y LIGHTING SERIES #LINK TALL	WALL MOUNTED	-	3000K LED	120V	9W	13.5" TALL x 8" WIDE x 4" DEEP WALL SCOFF WITH POLISHED CHROME FINISH, GLASS SHADE, ELECTRONIC DIMMING DRIVER.
I	NOT USED						
J	Y LIGHTING SERIES #CORONA	PENDANT	-	3000K LED	120V	8W	6" DIAMETER x 2" TALL SATIN ALUMINUM MINI PENDANT WITH ACRYLIC SHADE, ELECTRONIC DIMMING DRIVER.
K	HEALTHCARE LIGHTING SERIES # HPT624	RECESSED	-	7100 LUMEN 3500K LED	120V/277V	105W	2' x 4' MULTI-FUNCTION PATIENT TROFFER WITH AMBIENT AND EXAM FUNCTIONS, PERFORATED ACRYLIC INSERT, HIGH EXAM MODE, LOW VOLTAGE CONTROLLER INTERFACED WITH PULLOW SPEAKER TO CONTROL AMBIENT LIGHT, 0-10V DIMMING, MATTE WHITE FINISH.
UC	JUNO LIGHTING SERIES # UPS	UNDER CABINET	-	3000K LED	120V	12.5W	30" LONG x 3.5" DEEP x 1" TALL UNDER-CABINET LUMINAIRE WITH SOLID FRONT, POLY CARBONATE DIFFUSER, WHITE FINISH, ELECTRONIC DRIVER, PROVIDE WITH ALL REQUIRED JUMPER CORDS, CONNECTORS, MOUNTING HARDWARE, ETC.
X	LITHONIA LIGHTING SERIES # LRP	CEILING, BACK OR END MOUNT	-	LED	120V/277V	3W	EDGE-LIT EXIT SIGN WITH BRUSHED ALUMINUM HOUSING, AC ONLY. PROVIDE RED ON CLEAR FOR SINGLE FACE, OR RED ON MIRROR FOR DOUBLE FACE. PROVIDE MOUNTING, NUMBER OF FACES AND DIRECTIONAL ARROWS AS SHOWN ON DRAWINGS.

LIGHT FIXTURE SCHEDULE GENERAL NOTES

- REFER TO PLANS**
1. REFER TO THE GENERAL NOTES ON THE INFORMATION SHEET AND LIGHTING PLAN FOR ADDITIONAL INFORMATION.
- COMPLETE PART NUMBER**
2. COMPLETE LIGHTING FIXTURE MANUFACTURER PART NUMBERS ARE NOT SHOWN BUT SHALL BE OBTAINED FROM THE COMBINATION OF THE SERIES NUMBER, NUMBER OF LAMPS, TYPE OF LAMPS, VOLTAGE, AND DESCRIPTION. THE COMPLETE PART NUMBER FOR EACH LIGHT FIXTURE SHALL INCORPORATE THE REQUIREMENTS SHOWN ON THE LIGHT FIXTURE SCHEDULE, DRAWINGS, AND CONTRACT DOCUMENTS.
- BALLAST/DRIVER**
3. REFER TO SPECIFICATIONS FOR BALLAST/DRIVER REQUIREMENTS.
- LAMPS**
4. LAMP COLOR TEMPERATURE SHALL BE 3500K UNLESS INDICATED OTHERWISE IN OWNER GUIDELINES; CONFIRM EXACT COLOR TEMPERATURE OF LAMPS WITH OWNER PRIOR TO PURCHASING. MINIMUM CRI SHALL BE 85.
- FIXTURE MOUNTING HARDWARE & FINISH**
5. CONFIRM ALL CEILING TYPES, FINISHES, MOUNTING HARDWARE REQUIRED, AND PROJECT CONDITIONS PRIOR TO ORDERING NEW LIGHTING FIXTURES, LAMPS, AND BALLAST. PROVIDE FIXTURES WITH FLANGED MOUNTING KITS WHERE REQUIRED.
- ACCEPTABLE MANUFACTURERS**
6. MANUFACTURERS OTHER THAN THOSE LISTED IN THE DRAWINGS ARE ACCEPTABLE; REFER TO THE SPECIFICATIONS IF APPLICABLE. SHOULD THE CONTRACTOR SELECT A DIFFERENT MANUFACTURER THAN THOSE LISTED OR SPECIFIED, IT WILL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CONFIRM THAT ALL FIXTURES AND REQUIRED ACCESSORIES ARE EQUIVALENT AND SUITABLE FOR PROJECT CONDITIONS (CEILING TYPES, ENVIRONMENT, SPACE LIMITATIONS, LIGHT DISTRIBUTION, ETC.) THE OWNER MUST ALSO GIVE APPROVAL OF PROPOSED MANUFACTURER(S).
- SUBMITTALS**
7. SUBMISSION OF VENDOR/SHOP DRAWINGS FOR APPROVAL SHALL BE CONSTRUED THAT ALL CONTRACT DOCUMENT LIGHTING REQUIREMENTS HAVE BEEN INCLUDED AND THAT THE CONTRACTOR HAS VERIFIED EVERY LIGHTING FIXTURE VOLTAGE, QUANTITY OF BALLASTS, QUANTITY OF LAMPS, LAMP COLOR TEMPERATURE, AND MOUNTING WITH THE BUILDING CONDITIONS.

NOTICE TO CONTRACTORS:
HCA MAINTAINS PURCHASING AGREEMENTS FOR ACQUIRY BRANDS LIGHTING PRODUCTS. CONTRACTORS SHALL CONTACT HCA'S PREFERRED DISTRIBUTOR TO OBTAIN ALTERNATIVE COMPETITIVE PRICING.
GRAYBAR ELECTRIC CO., INC.
ATTN: JESS HOOVER
PHONE: 239-494-2088
EMAIL: HCA@GRAYBAR.COM
VENDOR REFERENCE: #947581

ABBREVIATIONS

A	AMPERES
AC	ABOVE COUNTER
ACCH	AIR COOLED CHILLER
ACCU	AIR COOLED CONDENSING UNIT
AFG	ABOVE FINISHED FLOOR
AF	ABOVE FINISHED GRADE
AHU	AIR HANDLING UNIT
ASC	ABOVE SUSPENDED CEILING
ATS	AUTOMATIC TRANSFER SWITCH
B	BOILER
BC	BELOW COUNTER
BSB	BUILDING SWITCHBOARD
CB	CONDUIT
C	CIRCUIT BREAKER
CEB	CONCRETE EQUIPMENT BASE
CLG	CEILING
CT	COOLING TOWER
CUH	CABINET UNIT HEATER
(D)	EXISTING TO BE REMOVED
(E)	EXISTING TO REMAIN
E.C.	ELECTRICAL CONTRACTOR
ECB	ENCLOSED CIRCUIT BREAKER
EM	EMERGENCY
EWC	ELECTRIC WATER COOLER
FAAP	FIRE ALARM ANNUNCIATOR PANEL
FACP	FIRE ALARM CONTROL PANEL
FCU	FAN COIL UNIT
FLA	FULL LOAD AMPERES
FUR	FURNACE
G	ISOLATED GROUND
G.C.	GENERAL CONTRACTOR
GFI	GROUND FAULT CIRCUIT INTERRUPTER
G	GROUND
GUH	GAS UNIT HEATER
HP	HORSEPOWER
HPU	HEAT PUMP UNIT
JB	JUNCTION BOX
KVA	KILO-VOLT AMPERES
KW	KILOWATT
LTS	LIGHTS
M.C.	MECHANICAL CONTRACTOR
MCA	MINIMUM CIRCUIT AMPACITY
MCC	MOTOR CONTROL CENTER
MDP	MAIN DISTRIBUTION PANEL
MIN	MINIMUM
MCCP	MAXIMUM OVERCURRENT PROTECTION
MOD	MOTOR OPERATED DAMPER
MTC	EMPTY CONDUIT
(N)	NEW
NF	NON-FUSED
NL	NIGHT LIGHT
OH	OVERHEAD
P	PUMP
PC	PHOTO CELL
PH,#	PHASE
PNL	PANEL
PP	POWER POLE
PRI	PRIMARY
(R)	EXISTING TO BE RELOCATED
RECEP	RECEPTACLE(S)
REFR	REFRIGERATOR
RTU	ROOFTOP UNIT
S/N	SOLID NEUTRAL
SEC	SECONDARY
TC	TIME CLOCK
TR	TAMPER-RESISTANT
TB	TELEPHONE TERMINAL BOARD
TYP	TYPICAL
UG	UNDERGROUND
UH	UNIT HEATER
USB	RECEPTACLE WITH USB (RE: SPECIFICATIONS)
V	VOLTS
VAV	VAV AIR TERMINAL
W	WIRE
WH	WATER HEATER
WM	WIRE MOLD
WR	WEATHER-RESISTANT
XFMR	TRANSFORMER

NOTE: NOT ALL ABBREVIATIONS MAY BE USED.

SYMBOL LEGEND

SYMBOL	DESCRIPTION
	HOMERUN. 2#12, 1#12G, 1/2" C UNLESS OTHERWISE NOTED.
	EXISTING PANELBOARD.
	NEW PANELBOARD.
	ISOLATION PANEL. REFER TO PLANS AND SPECIFICATIONS.
	RECESSED RECTILINEAR LIGHT FIXTURE. UPPER CASE LETTER INDICATES TYPE, REFER TO LIGHT FIXTURE SCHEDULE. LOWER CASE LETTER(S) INDICATES SWITCH LEG(S).
	SUSPENDED/SURFACE MOUNTED RECTILINEAR LIGHT FIXTURE. UPPER CASE LETTER INDICATES TYPE, REFER TO LIGHT FIXTURE SCHEDULE. LOWER CASE LETTER(S) INDICATES SWITCH LEG(S).
	RECESSED ROUND LIGHT FIXTURE. UPPER CASE LETTER INDICATES TYPE, REFER TO LIGHT FIXTURE SCHEDULE. LOWER CASE LETTER(S) INDICATES SWITCH LEG(S).
	SUSPENDED/SURFACE MOUNTED ROUND LIGHT FIXTURE. UPPER CASE LETTER INDICATES TYPE, REFER TO LIGHT FIXTURE SCHEDULE. LOWER CASE LETTER(S) INDICATES SWITCH LEG(S).
	WALL MOUNTED LIGHT FIXTURE. UPPER CASE LETTER INDICATES TYPE, REFER TO LIGHT FIXTURE SCHEDULE. LOWER CASE LETTER(S) INDICATES SWITCH LEG(S).
	SINGLE CROSS HATCHING ON ANY LIGHT FIXTURE INDICATES LIGHT FIXTURE IS ON A CRITICAL POWER CIRCUIT.
	CRISS-CROSS HATCHING ON ANY LIGHT FIXTURE INDICATES LIGHT FIXTURE IS ON A LIFE SAFETY POWER CIRCUIT.
	ANY LIGHT FIXTURE WITH A DOT INDICATES LIGHT FIXTURE HAS AN INTERNAL BATTERY BACKUP SYSTEM.
	CEILING MOUNTED EXIT LIGHT. FIXTURE TYPE X, REFER TO LIGHT FIXTURE SCHEDULE.
	WALL MOUNTED EXIT LIGHT. FIXTURE TYPE X, REFER TO LIGHT FIXTURE SCHEDULE.
	SINGLE POLE SWITCH, 20A-120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG.
	3-WAY SWITCH, 20A-120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG.
	4-WAY SWITCH, 20A-120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG.
	0-10V DIMMER. LUTRON NOVA OR EQUIVALENT. PROVIDE WITH POWER PACK FOR ON/OFF CAPABILITY IF DIMMING LED LOADS.
	SINGLE BUTTON DUAL TECHNOLOGY WALL SWITCH OCCUPANCY SENSOR, 120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG. WATTSTOPPER #DW-100.
	TWO BUTTON DUAL TECHNOLOGY WALL SWITCH OCCUPANCY SENSOR, 120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTERS INDICATE SWITCH LEGS. WATTSTOPPER #DW-200.
	MULTI-WAY SINGLE BUTTON DUAL TECHNOLOGY WALL SWITCH OCCUPANCY SENSOR, 120/277V. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG. WATTSTOPPER #DW-103.
	CEILING MOUNTED DUAL TECHNOLOGY OCCUPANCY SENSOR, 120/277V. LOWER CASE LETTER INDICATES SWITCH LEG. WATTSTOPPER #DT-355.
	PHOTOCELL FOR DUSK TO DAWN CONTROL. INTERMATIC #K4321C(120V) OR #K4023C(277V). FAILSAFE "ON".
	ON/OFF 0-10V DIMMING PIR WALL SWITCH OCCUPANCY SENSOR, MULTI-LOCATION CAPABLE. 48" AFF TO CENTERLINE. LOWER CASE LETTER INDICATES SWITCH LEG. LUTRON MAESTRO #MS-Z101.
	DUPLEX RECEPTACLE, 20A-125V, NEMA 5-20R. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	TWO DUPLEX RECEPTACLES IN 2-GANG BOX WITH SINGLE COVER PLATE, 20A-125V, NEMA 5-20R. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	SPECIAL PURPOSE RECEPTACLE, AS NOTED. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	FLUSH FLOOR MOUNTED DUPLEX RECEPTACLE.
	DUPLEX RECEPTACLE, 20A-125V, NEMA 5-20R, WITH "IN-USE" WEATHER-RESISTANT COVER. 24" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	GROUND FAULT CIRCUIT INTERRUPTER DUPLEX RECEPTACLE, 20A-125V, NEMA 5-20R. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	EMERGENCY POWERED RED DUPLEX RECEPTACLE, 20A-125V, NEMA 5-20R. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	TWO EMERGENCY POWERED RED DUPLEX RECEPTACLES IN 2-GANG BOX WITH SINGLE COVER PLATE, 20A-125V, NEMA 5-20R. 18" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED.
	FOUR EMERGENCY POWERED RED DUPLEX RECEPTACLES IN 4-GANG POWER GROUND MODULE BOX, 20A-125V, NEMA 5-20R. 42" AFF TO CENTERLINE, UNLESS OTHERWISE NOTED. SEE SPECIFICATIONS.
	MOTOR CONNECTION. MAKE FINAL MOTOR CONNECTION.
	ELECTRICAL CONNECTION. MAKE FINAL CONNECTION.
	MANUAL MOTOR SWITCH. FRANKLIN CONTROLS SYSTEMS #BAS-1P. PROVIDE NEMA 3R ENCLOSURE WHERE INSTALLED OUTDOORS.
	DISCONNECT SWITCH, SIZE AND FUSING AS NOTED. "NF" INDICATES NON-FUSED. "WR" INDICATES WEATHER-RESISTANT.
	COMBINATION MOTOR STARTER AND DISCONNECT SWITCH, SIZE, TYPE AND FUSING AS NOTED. "NF" INDICATES NON-FUSED. "WR" INDICATES WEATHER-RESISTANT.
	MOTOR STARTER, SIZE AND TYPE AS NOTED.
	VARIABLE FREQUENCY DRIVE, AS NOTED.
	JUNCTION BOX. SIZE AS REQUIRED.
	PULL BOX. SIZE AS REQUIRED.

NOTE: NOT ALL SYMBOLS MAY BE USED.

GENERAL PROJECT NOTES

- ALL ELECTRICAL DRAWINGS ARE DIAGRAMMATIC. CONTRACTOR SHALL VISIT THE SITE PRIOR TO BID AND START OF CONSTRUCTION TO DETERMINE THE EXISTING CONDITION OF THE ELECTRICAL SYSTEMS AND DEVICES. CONTRACTOR WILL BE RESPONSIBLE FOR REVIEWING ANY DOCUMENTATION WHICH REFLECT THE EXISTING CONDITIONS. COORDINATE ALL OUTLET/DEVICE LOCATION, CONNECTION TYPE, AND TERMINATION REQUIREMENTS WITH OTHER DISCIPLINES, ARCHITECTURAL PLANS AND EQUIPMENT INSTALLERS/MANUFACTURERS PRIOR TO ROUGH-IN.
- ALL WORK SHALL COMPLY WITH ALL PERTINENT NATIONAL, AMERICAN DISABILITIES ACT (ADA), TEXAS ACCESSIBILITY STANDARDS (TAS), STATE, LOCAL ORDINANCE CODES AND REQUIREMENTS.
- ALL EQUIPMENT, MATERIALS, AND INSTALLATION METHODS AS OUTLINED IN THE SPECIFICATIONS SHALL APPLY TO THIS PROJECT.
- ELECTRICAL GENERAL NOTES ON ANY SHEET SHALL APPLY TO ALL OTHER ELECTRICAL SHEETS UNLESS INDICATED OTHERWISE.
- STANDARD DETAILS ILLUSTRATED ON THE DRAWINGS SHALL BE APPLIED IN ALL CASES WHERE THE FEATURE OCCURS IN THE SYSTEM DESIGN.
- PROVIDE ALL NEW CONDUIT UNLESS NOTED OTHERWISE. MINIMUM CONDUIT SIZE SHALL BE 1/2" UNLESS INDICATED OTHERWISE.
- ALL OUTDOOR CONDUIT SHALL BE LISTED AND SUITABLE FOR THE ENVIRONMENT WHICH IT'S TO BE INSTALLED IN (NEC 300.6). IN ADDITION, NEW CONDUIT EXPOSED TO THE WEATHER SHALL BE LISTED AS SUNLIGHT RESISTANT. ALL CONDUIT COUPLING AND CONNECTORS EXPOSED TO THE OUTSIDE SHALL BE WEATHERPROOF, RAINPROOF, AND RAIN/TIGHT/WATER-TIGHT.
- PROVIDE ALL NEW CONDUCTORS UNLESS NOTED OTHERWISE. CONDUCTORS SHALL BE COPPER WITH INSULATION RATED NO LESS THAN 75 DEGREES CELSIUS. THHN/THWN UNLESS NOTED OTHERWISE. CONDUCTOR TERMINATIONS SHALL MATCH OR EXCEED THE RATING OF THE CONDUCTORS.
- ALL WIRING AND CABLEING SHALL BE INSTALLED IN CONDUIT UNLESS NOTED OTHERWISE.
- THE MINIMUM WIRE SIZE FOR ALL NEW CONDUCTORS SHALL BE #12 AWG COPPER FOR ALL SHORT DISTANCE RUNS. ALL 120V AND 277 CIRCUIT CONDUCTORS EXCEEDING 50 FEET (100 FEET FOR 277V) IN LENGTH SHALL BE A MINIMUM OF #10 WIRE. THE LARGEST CONDUCTOR SIZE SHALL BE USED IF ANY DISCREPANCY BETWEEN THE CONSTRUCTION DOCUMENTS AND/OR BUILDING STANDARDS OCCUR.
- RAISE, OFFSET, LOWER, AND EXTEND EXISTING BRANCH CIRCUITS AS NEEDED.
- JUNCTION BOXES MUST BE INDEPENDENTLY MOUNTED ON GALVANIZED STEEL CHANNELS AND PER NEC. FOR ALL JUNCTION BOXES THAT ARE PART OF THE SCOPE, PERMANENTLY MARK ON THE COVER PLATE THE ASSOCIATED CIRCUIT NUMBER AND VOLTAGE.
- PROVIDE NEW THERMAL MAGNETIC CIRCUIT BREAKERS FOR ALL EQUIPMENT AND DEVICES UNLESS INDICATED OTHERWISE. THE NEW CIRCUIT BREAKER SHALL MATCH THE PANELBOARD'S MANUFACTURER, BREAKER TYPE (THERMAL MAGNETIC OR GREATER), A.I.C. RATING, AND SHALL BE FULLY RATED (NO SERIES RATING ALLOWED). PROVIDE HACR TYPE CIRCUIT BREAKERS FOR ALL HEATING, AIR CONDITIONING, AND REFRIGERATION EQUIPMENT. UPDATE THE PANELBOARD DIRECTORY AS REQUIRED.
- IN THE EVENT ANY DISCREPANCIES OCCUR BETWEEN ARCHITECTURAL, MECHANICAL, PLUMBING, ELECTRICAL, AND OTHER DRAWINGS OR SPECIFICATIONS; CONTRACTOR IS TO INCORPORATE IN THE BID PRICE THE MOST STRINGENT OPTION. CONTRACTOR SHALL PROVIDE ALL NECESSARY ADDITIONAL ELECTRICAL COMPONENTS IF EQUIPMENT PURCHASED DIFFERS FROM WHAT IS SPECIFIED IN THE CONTRACT DOCUMENTS.

DRAWING INDEX

NUMBER	DRAWING TITLE
EO.00	INFORMATION SHEET - ELECTRICAL
EO.01	PANEL SCHEDULES - ELECTRICAL
E1.01	PARTIAL DEMOLITION PLAN - ELECTRICAL - AREA 1
E1.02	PARTIAL DEMOLITION PLAN - ELECTRICAL - AREA 2
E2.01	PARTIAL FLOOR PLAN - LIGHTING - AREA 1
E2.02	PARTIAL FLOOR PLAN - LIGHTING - AREA 2
E3.01	PARTIAL FLOOR PLAN - POWER - AREA 1
E3.02	PARTIAL FLOOR PLAN - POWER - AREA 2
E4.00	PARTIAL OVERALL 1ST FLOOR PLAN - EQUIPMENT POWER
E4.01	PARTIAL FLOOR PLAN - EQUIPMENT POWER - AREA 1
E4.02	PARTIAL FLOOR PLAN - EQUIPMENT POWER - AREA 2
E5.01	PARTIAL FLOOR PLAN - SPECIAL SYSTEMS - AREA 1
E5.02	PARTIAL FLOOR PLAN - SPECIAL SYSTEMS - AREA 2
E6.01	DETAILS - ELECTRICAL
MEP6.01	TEMPORARY AHU PLAN - MECHANICAL, ELECTRICAL & PLUMBING

HEITKAMP SWIFT ARCHITECTS
Architecture • Interiors • Planning
1165 BRITTMOORE RD.
HOUSTON, TEXAS 77043
(713) 626-4300
(713) 626-4301

in association with:

Garner-Fritzsche ENGINEERING, INC.
8554 Katy Freeway, Suite 101, Houston, TX 77024
713.432.1422 • Fax 713.432.1253
www.garnerfritzsche.com
Texas Reg. No. F-5712
GEF Project No. 18022

{b} bennett design group
1165 Brittmoores Rd.
Houston, Texas 77043
p: 713.850.8833 f: 713.850.0383

Rio Grande REGIONAL HOSPITAL
An HCA Affiliated Hospital

3rd Floor INPATIENT REHAB UNIT

FOR INTERIM REVIEW ONLY
THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW ONLY UNDER THE AUTHORITY OF:
Name: GREG W. MERCER
P.E. No: 114433
DATE: 09/06/2018
AND IS NOT INTENDED TO BE USED FOR BIDDING OR CONSTRUCTION PURPOSES.

REVISIONS

NO.	ISSUE	DATE

Sheet Information
DATE: 09/06/2018
JOB NUMBER: 18302
TITLE: INFORMATION SHEET - ELECTRICAL SHEET

E0.00
ISSUED FOR PRICING ONLY

Copyright © 2018 Heitkamp Swift Architects