

NOTE

FIRE RATING OF COMPLETED FIREPROOFED ASSEMBLY SHALL EQUAL OR EXCEED THE FIRE RATING OF THE FLOOR

3 FLOOR PENETRATION DETAIL

NOT TO SCALE



NOTE

FIRE RATING OF COMPLETED FIREPROOFED ASSEMBLY SHALL EQUAL OR EXCEED THE FIRE RATING OF THE WALL

2 FIRE WALL PENETRATION DETAIL

NOT TO SCALE



PROVIDE ENGRAVED FACEPLATES FOR RECEPTACLES AND LIGHT SWITCHES INDICATING THE PANELBOARD AND THE SUPPLY BRANCH CIRCUIT NUMBER. REFER TO SPECIFICATIONS FOR MORE INFORMATION.

1 ELECTRICAL DEVICE IDENTIFICATION

NOT TO SCALE

HEITKAMP SWIFT
ARCHITECTS
Architecture • Interiors • Planning
1165 BRITTMOORE RD.
HOUSTON, TEXAS 77043
(T) 713.626.4300
(F) 713.626.4301

in association with:

Garner-Fritsche ENGINEERING, INC.
8554 Katy Freeway, Suite 101, Houston, TX 77024
713.432.1422 - Fax 713.432.1253
www.garnerfritsche.com
Texas Reg. No. F-5712
GFE Project No. 18022

bennett design group
1165 Brittmoore Rd.
Houston, Texas 77043
p: 713.850.8833 f:713.850.0383

Rio Grande REGIONAL HOSPITAL
An HCA Affiliated Hospital

3rd Floor
INPATIENT
REHAB UNIT

FOR INTERIM REVIEW ONLY
THIS DOCUMENT IS RELEASED FOR THE PURPOSE OF INTERIM REVIEW ONLY, UNDER THE AUTHORITY OF:
Name: GREG W. MERCER
P.E. No. 114431
DATE: 09/06/2018
AND IS NOT INTENDED TO BE USED FOR BIDDING OR CONSTRUCTION PURPOSES.

REVISIONS

NO.	ISSUE	DATE

Sheet Information

DATE	09/06/2018
JOB NUMBER	18302

TITLE
DETAILS - ELECTRICAL

SHEET
E6.01
ISSUED FOR PRICING ONLY

Copyright © 2018 Heitkamp Swift Architects

Sep 06, 2018 - 9:19am
M:\2018\18022 HCA RGRH Inpatient Rehab\Dwgs\Elec\18022_E6.01_DETAILS - ELECTRICAL.dwg
crothlauf