

November 9, 2018

Los Fresnos, Texas 78566 PH (956) 233-2218

400 E. 3"

Name of Project:Cameron Appraisal District Addition and RenovationAddress:2021 Amistad DriveSan Benito, TX 78586

### Addendum #2

The following items shall be addressed and considered as part of the the plans and specifications for a complete bid on this project

Reference to the Owner, Cameron Appraisal District, shall be noted as "CAD" in this document.

### **Specifications**

Table of Contents revised to include:

075419 – Polyvinyl-Chloride Roofing - Single Ply Roof Membrane Specification is added as the Roofing specification for the New Addition. Provide insulation thickness for R38 Value in material as specified.

09511 - Acoustical Panel Ceilings

1. Products in the Specifications refer to New Ceilings in the New Addition.

2. For the Existing Building use Armstrong 942.

10425 – Signage – All signage shall be addressed as part of the \$10,000.00 Allowance for bid purposes. This Allowance shall be a separate line item on the G702 Application for Payment and shall not include Overhead and Profit in the amount. Any dollar amount balance left at completion of the project shall be refunded to CAD at the final Application for Payment. During construction CAD and Architect will provide a detailed list of signage required for Addition and Existing Building, exterior, interior and plaque for pricing.

Also on Drawings A1.1 and R-A1.1 - Signage is no longer by Owner

### **Drawings**

R-A4 - Room Finish Schedule - For the Existing Building,

- 1. Remove flooring and Install New VCT Flooring for following rooms: Vestibule 101, Waiting Area 102, Storage 117, Hall 119, Reception 121, & Hall 141 to Main Hall face of Room 140.
- 2. Remove flooring and Install New Ceramic Tile for following rooms: Executive RR 118, Mens RR1, Womens RR1, Mens RR2, & Womens RR2
- 3. For Tax office 103 and Data Entry 123, Remove flooring and Install New VCT flooring for first 7 feet for full width of the room (approx. 21 ft) from door adjoining Waiting Room into the space.
- 4. The ceramic tile for the restroom walls and floor is partially supplied by Owner, see following list of materials. As the material is identified, the \$6.00 Allowance for the balance of the work is

deleted from the bid documents and contractor can identify his own price for materials and labor. Tile will be delivered when required.

a. Interceramic Tile

Castelbianco/Vesallo Smoke 20x20 Tile- for the Floor Castelbianco/Vesallo Smoke 12x24 Tile- for the Walls Castelbianco/Vesallo Smoke 13x11 Hexagon Mosaic- for the border Castelbianco/Vesallo Smoke 6x13 Cove Base Tile- for the base

Tex-Rite- Grout White or Gray

this is a porcelain tile and it needs to be installed with Mapei Ultrafkex thin set for both floor and wall.

A-4 - Window Types, Door Schedule & Window Schedule & A5 Detail #7 – Door Frame B and Door 2 to be Aluminum Storefront instead of Hollow Metal and need not be fire rated glass.

S1.0 – Notes - Roof repairs to meet TDI: The roofer/supplier shall submit the manufacturer tests (ie. NOA, TrinityERD, etc.) to meet the required pressures listed on S1.0. Durolast roof is accepted as a single ply Fully Adhered Roof for the Addition Refer to architectural for roof membrane type. Roof covering shall meet performance requirements listed on S1.0.

ALL FILL INCLUDING TUNNELING BACKFILL WILL NEED TO MEET COMPACTION REQUIREMENTS AS DESCRIBED ON \$1.0.

S5.0 Clarification: Use Detail 15/S6.0 for CMU walls. Use Detail 25/S6.1 for metal stud walls.

S6.0 Details 10,11, 12, 13 & 14 - Furring Channel change Stud to 3 5/8" 16 ga.

S6.1; Detail 24/S6.1 is shown for illustration purposes only. Use Detail 1/S5.0. RTU assembly to meet design criteria shown in S1.0.

R-A1.2 Circles shown refer to recessed lighting be under new canopy that are shown on R-E3.1 were changed to wall mounted and are relocated as shown in enclosed AXI drawing

R-E3.1, Relocate light fixture DE and Add new recessed fixture above window at Reception by Waiting Area as shown on enclosed plan R-E3.1a.

R-E4.1a, AV - Fire Alarm Strobe horn added to Vestibule.

A2.1 Roof Plan: Note states single ply roof. There is no specification section for single ply roof, please provide specification and warranty period required.

D-A2 Existing roof notes:

- 1. Replace Exposed Roof felts: With type of felt that is exposed i.e. type IV, Type VI, and/or base Sheet. Ballast is noted for Gravel.
- 2. Rebuild area around 3 Roof Drains and Replace one Damaged roof drains and Remove and Repair Roof at one Abandoned Roof Drain.

- 3. All roof drains will be reworked with new lead flashing and apply new tapered insulation as required to eliminate ponding around the roof drain. This occurs on 3 Roof Drains for a 5ft x 5ft area.
- 4. There are no active Roof Leaks at this time.

Grid and Ceiling replacement after installation of overhead items in the existing building due to sprinkler system, and MEP scope of work is expected to be different for each trade thus General Contractor to include cost of repair and/or replacement as part of their bid on the work.

# **TABLE OF CONTENTS**

## CAMERON APPRAISAL DISTRICT - NEW BUILDING ADDITION & RENOVATIONS

#### **DIVISION 0**

- 00020 INVITATION TO BID
- 00100 INSTRUCTION TO BIDDERS
- 00120 SUPPLEMENTARY INSTRUCTIONS TO BIDDERS
- 00220 GEOTECHNICAL DATA
- 00301 BID FORM
- 00410 BID BOND FORM
- 00500 AGREEMENT FORM
- 00700 GENERAL CONDITIONS
- 00800 SUPPLEMENTARY CONDITIONS
- 00801 DRAWING INDEX

#### **DIVISION 1 - GENERAL REQUIREMENTS**

- 01010 SUMMARY OF WORK
- 01019 GENERAL SPECIFICATIONS
- 01027 APPLICATION FOR PAYMENT
- 01028 CHANGE ORDER PROCEDURE
- 01100 SPECIAL PROVISIONS
- 01150 BETTERMENT FUND
- 01231 RANKING CRITERIA
- 01300 ADMINISTRATIVE REQUIREMENTS
- 01301 SUBMITTALS, PRODUCTS & SUBSTITUTIONS
- 01310 STRUCTURAL WIND PRESSURE REQUIREMENTS
- 01320 CONSTRUCTION PROGRESS DOCUMENTATION
- 01330 SUBMITTAL PROCEDURES
- 01400 QUALITY REQUIREMENTS
- 01410 TESTING LABORATORY SERVICES
- 01500 TEMPORARY FACILITIES AND CONTROLS
- 01567 POLLUTION CONTROL
- 01600 PRODUCT REQUIREMENTS
- 01605 WARRANTIES AND MAINTENANCE
- 01620 STORAGE AND PROTECTION
- 01700 CONTRACT CLOSEOUT
- 01731 CUTTING AND PATCHING

#### **DIVISION 2 - SITE CONSTRUCTION**

02810 TERMITE CONTROL

#### **DIVISION 3 - CONCRETE**

03231 ALUMINUM FENCE

#### **DIVISION 4 – MASONRY**

04810 UNIT MASONRY ASSEMBLIES

#### **DIVISION 5 – METALS**

05500 METAL FABRICATION

#### **DIVISION 6 - WOOD AND PLASTICS**

- 06100 ROUGH CARPENTRY
- 06105 MISCELLANEOUS CARPENTRY
- 06161 INSULATING SHEATHING ZIP SYSTEM
- 06200 FINISH CARPENTRY
- 06300 TECHSHIELD RADIANT BARRIER

#### **DIVISION 7 - THERMAL AND MOISTURE PROTECTION**

07160 BITUMINOUS DAMPPROOFING

- 07265 VAPOR RETARDER AIR BARRIER
- 07272 PENETRATION SEALS
- 07541 POLYVINYL-CHLORIDE ROOFING
- 07591 MEMBRANE REROOFING PREPARATION
- 07610 METAL ROOFING -CRAFTSMAN
- 07620 SHEET METAL FLASHING AND TRIM
- 07901 WATERPROOFING, CAULKING & DAMPROOFING
- 07920 SEALANTS, CAULKING & SEALS
- 07951 INTERIOR SEISMIC EXPANSION CONTROL SYSTEM

#### **DIVISION 8 - DOORS AND WINDOWS**

- 08100 HOLLOW METAL DOORS AND FRAMES
- 08110 STEEL DOOR AND FRAMES
- 08200 FLUSH WOOD DOORS
- 08520 ALUMINUM WINDOWS
- 08710 FINISH HARWARE ADDITION BUILDING
- 08710 FINISH HARDWARE EXISTING BUILDING
- 08800 GLASS & GLAZING

#### **DIVISION 9 – FINISHES**

- 09225 POLYMER/FIBER MODIFIED STUCCO SYSTEM
- 09250 GYPSUM DENS-GLASS GOLD SHEATHING
- 09260 GYPSUM BOARD ASSEMBLIES
- 09305 DENS-SHEILD
- 09310 CERAMIC TILE
- 09511 ACOUSTICAL PANEL CEILINGS
- 09651 RESILIENT FLOOR TILE
- 09653 RESILIENT WALL BASE & ACCESSORIES
- 09900 PAINT

## **DIVISION 10 – SPECIALTIES**

- 10425 IDENTIFYING DEVICES
- 10520 FIRE EXTINGUISHERS & CABINETS
- 10801 TOILET AND BATH ACCESSORIES

### **DIVISION 12 – FURNISHINGS**

12361 QUARTZ COUNTERTOPS



## **Duro-Last Roof Assembly Description**

## **Duro-Last® PVC thermoplastic membrane**

Membrane Thickness: 50 mil Color: White

Attachment: Adhered with water-based adhesive

# **SECUROCK® Gypsum-Fiber Roof Board**

Thickness: 1/4 inch

Attachment: Attached with Duro-Grip® Insta-Stik insulation adhesive

## Duro-Guard® ISO II (tapered)

Attachment: Attached with Duro-Grip® Insta-Stik insulation adhesive

#### Duro-Guard® ISO II (flat)

Attachment: Attached with Duro-Grip® Insta-Stik insulation adhesive

#### **Cementitious Wood Fiber (Tectum) Roof Deck**

## PART 1 GENERAL

## 1. SECTION INCLUDES

- A. Duro-Last® PVC thermoplastic membrane adhered with water-based adhesive.
- B. SECUROCK® Gypsum-Fiber Roof Board, attached with Duro-Grip® Insta-Stik insulation adhesive.
- C. Duro-Guard® ISO II (tapered), attached with Duro-Grip® Insta-Stik insulation adhesive.
- D. Duro-Guard® ISO II (flat), attached with Duro-Grip® Insta-Stik insulation adhesive.
- E. Prefabricated flashings, corners, parapets, stacks, vents, and related details.
- F. Fasteners, adhesives, and other accessories required for a complete roofing installation.
- G. Traffic Protection.

## 2. REFERENCES

- A. NRCA The NRCA Roofing and Waterproofing Manual.
- B. ASCE 7 Minimum Design Loads For Buildings And Other Structures.
- C. UL Roofing Materials and Systems Directory, Roofing Systems (TGFU.R10128).
- D. ASTM C 1289 Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board.
- E. ASTM D 751 Standard Test Methods for Coated Fabrics.
- F. ASTM D 4434 Standard Specification for Poly(Vinyl Chloride) Sheet Roofing.
- G. ASTM E 108 Standard Test Methods for Fire Tests of Roof Coverings.
- H. ASTM E 119 Standard Test Methods for Fire Tests of Building Construction and Materials.

## 3. SYSTEM DESCRIPTION

- A. General: Provide installed roofing membrane and base flashings that remain watertight; do not permit the passage of water; and resist specified uplift pressures, thermally induced movement, and exposure to weather without failure.
- B. Material Compatibility: Provide roofing materials that are compatible with one another under conditions of service and application required, as demonstrated by roofing membrane manufacturer based on testing and field experience.
- C. Physical Properties:
- D. Cool Roof Rating Council (CRRC):
  - 1. Membrane must be listed on CRRC website.
    - a. Initial Solar Reflectance:  $\geq 88\%$
    - b. Initial Thermal Emittance:  $\geq 87\%$
    - c. Initial Solar Reflective Index (SRI):  $\geq 111$
    - d. 3-Year Aged Solar Reflectance:  $\geq 68\%$
    - e. 3-Year Aged Thermal Emittance:  $\geq 84\%$

- f. 3-Year Aged Solar Reflective Index (SRI):  $\geq 82$
- E. Insulation
  - 1. Provide overall thermal resistance for roofing system as follows:
  - a. Minimum R-value: 25.
  - 2. Tapered Insulation Slope: 1/4 inch per foot.
  - 3. Configuration as indicated on the Drawings.

## 4. SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Duro-Last data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Installation methods.
  - 4. Maintenance requirements.
- C. Shop Drawings: Indicate insulation pattern, overall membrane layout, field seam locations, joint or termination detail conditions, and location of fasteners.
- D. Verification Samples: For each product specified, two samples, representing actual product, color, and finish.
  - 1. 4 inch by 6 inch sample of roofing membrane, of color specified.
  - 2. 4 inch by 6 inch sample of walkway pad.
  - 3. Termination bar, fascia bar with cover, drip edge and gravel stop if to be used.
  - 4. Each fastener type to be used for installing membrane, insulation/recover board, termination bar and edge details.
- E. Installer Certification: Certification from the roofing system manufacturer that Installer is approved, authorized, or licensed by manufacturer to install roofing system.
- F. Manufacturer's warranties.

## 5. QUALITY ASSURANCE

- A. Perform work in accordance with manufacturer's installation instructions.
- B. Manufacturer Qualifications: A manufacturer specializing in the production of PVC membranes systems and utilizing a Quality Control Manual during the production of the membrane roofing system that has been approved by and is inspected by Underwriters Laboratories.
- C. Installer Qualifications: Company specializing in installation of roofing systems similar to those specified in this project and approved by the roofing system manufacturer.
- D. Source Limitations: Obtain components for membrane roofing system from roofing membrane manufacturer.

E. There shall be no deviations from the roof membrane manufacturer's specifications or the approved shop drawings without the prior written approval of the designer.

## 6. REGULATORY REQUIREMENTS

- A. Conform to applicable code for roof assembly wind uplift and fire hazard requirements. Contractor must provide TDI windstorm certification from an engineer.
- B. Fire Exposure: Provide membrane roofing materials with the following fire-test-response characteristics. Materials shall be identified with appropriate markings of applicable testing and inspecting agency.
  - 1. Exterior Fire-Test Exposure:
    - a. Class A; ASTM E 108, for application and roof slopes indicated.
  - 2. Fire-Resistance Ratings: Comply with ASTM E 119 for fire-resistance-rated roof assemblies of which roofing system is a part.
  - 3. Conform to applicable code for roof assembly fire hazard requirements.
- C. Wind Uplift:
  - 1. Roofing System Design: Provide a roofing system designed to resist uplift pressures calculated according to the current edition of the ASCE-7 Specification *Minimum Design Loads for Buildings And Other Structures*.
  - 2. Contractor must provide TDI certification for the project

## 7. PRE-INSTALLATION MEETING

- A. Convene meeting not less than one week before starting work of this section.
- B. Review methods and procedures related to roof deck construction and roofing system including, but not limited to, the following.
  - 1. Meet with Owner, Architect, Owner's insurer if applicable, testing and inspecting agency representative, roofing installer, roofing system manufacturer's representative, deck installer, and installers whose work interfaces with or affects roofing including installers of roof accessories and roof-mounted equipment.
  - 2. Review and finalize construction schedule and verify availability of materials, installer's personnel, equipment, and facilities needed to make progress and avoid delays.
  - 3. Examine deck substrate conditions and finishes for compliance with requirements, including flatness and fastening.
  - 4. Review structural loading limitations of roof deck during and after roofing.
  - 5. Review base flashings, special roofing details, roof drainage, roof penetrations, equipment curbs, and condition of other construction that will affect roofing system.
  - 6. Review governing regulations and requirements for insurance and certificates if applicable.
  - 7. Review temporary protection requirements for roofing system during and after installation.
  - 8. Review roof observation and repair procedures after roofing installation.
- 8. DELIVERY, STORAGE AND HANDLING

- A. Deliver roofing materials to Project site in original containers with seals unbroken and labeled with manufacturer's name, product brand name and type, date of manufacture, and directions for storing and mixing with other components.
- B. Store liquid materials in their original undamaged containers in a clean, dry, protected location and within the temperature range required by roofing system manufacturer. Protect stored liquid material from direct sunlight.
- C. Protect roof insulation materials from physical damage and from deterioration by sunlight, moisture, soiling, and other sources. Store in a dry location. Comply with insulation manufacturer's written instructions for handling, storing, and protecting during installation.
- D. Store roof materials and place equipment in a manner to avoid permanent deflection of deck.
- E. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

## 9. WARRANTY

- A. Contractor's Warranty: The contractor shall warrant the roof application with respect to workmanship and proper application for two (2) years from the effective date of the warranty issued by the manufacturer.
- B. Manufacturer's Warranty: Must be no-dollar limit type and provide for completion of repairs, replacement of membrane or total replacement of the roofing system at the then-current material and labor prices throughout the life of the warranty. In addition the warranty must meet the following criteria:
  - 1. Warranty Period: 15 years from date issued by the manufacturer.
  - 2. No exclusions for incidental or consequential damages.
  - 3. No exclusion for damage caused by ponding water.
  - 4. No exclusion for damage caused by biological growth.
  - 5. Issued direct from and serviced by the roof membrane manufacturer.
  - 6. Transferable for the full term of the warranty.
  - 7. No additional charge for the warranty.

## PART 2 PRODUCTS

## 1. MANUFACTURER

- A. Manufacturer: Duro-Last Roofing, Inc., which is located at: 525 Morley Drive, Saginaw, MI 48601. Telephone: 800-248-0280.
- B. All roofing system components to be provided or approved by Duro-Last Roofing, Inc.
- C. Substitutions: Equal or greater substitutions must be submitted to the architect for approval 5 days before the bid is due using CSI form 13.1.A
- 2. ROOFING SYSTEM COMPONENTS
  - A. Roofing Membrane: Duro-Last® PVC thermoplastic membrane conforming to ASTM D 4434, type III, fabric-reinforced, PVC. Membrane properties as follows:
    - 1. Thickness:

- a. 50 mil.
- 2. Exposed Face Color:
  - a. White.
- B. Accessory Materials: Provide accessory materials supplied by or approved for use by Duro-Last Roofing, Inc.
  - 1. Sheet Flashing: Manufacturer's standard reinforced PVC sheet flashing.
  - 2. Duro-Last Factory Prefabricated Flashings: manufactured using Manufacturer's standard reinforced PVC membrane.
    - a. Stack Flashings.
    - b. Curb Flashings.
    - c. Inside and Outside Corners.
  - 3. Sealants and Adhesives: Compatible with roofing system and supplied by Duro-Last Roofing, Inc.
    - a. Duro-Grip<sup>®</sup> Insta-Stik<sup>™</sup> Insulation Adhesive.
    - b. Duro-Caulk® Plus.
    - c. Strip Mastic.
  - 4. Slip Sheet: Compatible with roofing system and supplied by Duro-Last Roofing, Inc.
  - 5. Fasteners and Plates: Factory-coated steel fasteners and metal or plastic plates meeting corrosion-resistance provisions in FMG 4470, designed for fastening membrane and insulation to substrate. Supplied by Duro-Last Roofing, Inc.
    - a. Auger Fasteners.
  - 6. Termination and Edge Details: Supplied by Duro-Last Roofing, Inc.
    - a. Termination Bar.
    - b. Kynar Steel Fascia Cover.
  - 7. Vinyl Coated Metal: Supplied by Duro-Last Roofing, Inc. 24 gauge, hot-dipped galvanized, grade 90 metal with a minimum of 17 mil of Duro-Last membrane laminated to one side.
- C. Substrate Board:
- D. Walkways:
  - 1. Provide non-skid, maintenance-free walkway pads in areas of heavy foot traffic and around mechanical equipment.
    - a. Duro-Last Roof Trak® III Walkway Pad.

## 3. ROOF INSULATION

- A. General:
  - 1. Provide preformed roof insulation boards that comply with requirements and referenced standards, as selected from manufacturer's standard sizes.
  - Provide 2 layers of polyisocyanurate board min 2" Stagger joints with each layer. Minimum R25
  - 3. Provide preformed saddles, crickets, and other insulation shapes where indicated for sloping

to drain. Fabricate to slopes indicated.

- B. Polyisocyanurate Board Insulation: Complying with ASTM C 1289, Type II, felt or glass-fiber mat facer on both major surfaces. Material as supplied by Duro-Last.
  - 1. Duro-Guard® ISO II (flat).
  - 2. Duro-Guard® ISO II (tapered).

### 4. ROOF INSULATION ACCESSORIES

- A. General: Provide roof insulation accessories approved by the roof membrane manufacturer and as recommended by insulation manufacturer for the intended use.
- B. Insulation Adhesive: Provide Duro-Grip insulation adhesive for attaching insulation and/or insulation cover boards in conformance to specified design requirements.
  - 1. Duro-Grip<sup>®</sup> Insta-Stik<sup>™</sup> insulation adhesive.
  - 1. SECUROCK® Gypsum-Fiber Roof Board as manufactured by United States Gypsum Company.
    - a.  $\frac{1}{4}$  inch thick.

## **PART 3 EXECUTION**

- 1. EXAMINATION
  - A. Verify that the surfaces and site conditions are ready to receive work.
  - B. Verify that the deck is supported and secured.
  - C. Verify that the deck is clean and smooth, free of depressions, waves, or projections, and properly sloped to drains, valleys, eaves, scuppers or gutters.
  - D. Verify that the deck surfaces are dry and free of standing water, ice or snow.
  - E. Verify that all roof openings or penetrations through the roof are solidly set.
  - F. If substrate preparation is the responsibility of another contractor, notify Architect of unsatisfactory preparation before proceeding.

## 2. PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Surfaces shall be clean, smooth, free of fins, sharp edges, loose and foreign material, oil, grease, and bitumen.

## 3. INSTALLATION

- A. Install insulation in accordance with the roof manufacturer's requirements.
- B. Insulation: Duro-Guard® ISO II (flat) and Duro-Guard® ISO II (tapered).
  - 1. Install insulation in accordance with the roof manufacturer's requirements.
  - 2. Insulation shall be adequately supported to sustain normal foot traffic without damage.

- 3. Where field trimmed, insulation shall be fitted tightly around roof protrusions with no gaps greater than <sup>1</sup>/<sub>4</sub> inch.
- 4. Tapered insulation boards shall be installed in accordance with the insulation manufacture's shop drawings.
- 5. No more insulation shall be applied than can be covered with the roof membrane by the end of the day or the onset of inclement weather.
- 6. If more than one layer of insulation is used, all joints between subsequent layers shall be offset by at least 6 inches.
- C. Insulation Cover Board: SECUROCK® Gypsum-Fiber Roof Board.
- D. Roof Membrane: 50 mil, Duro-Last® PVC thermoplastic membrane.
  - 1. Use only membrane adhesive acceptable to the roof manufacturer's that meets the applicable design requirements.
    - a. Water-based membrane adhesive.
  - 2. Cut membrane to fit neatly around all penetrations and roof projections.
  - 3. Unroll roofing membrane and positioned with a minimum 6 inch overlap.
  - 4. Apply adhesive in accordance with the roof manufacturer's requirements.
    - a. Apply at the required rate in smooth, even coatings without voids, globs, puddles or similar irregularities. Use care not to contaminate the area of the membrane where hot air welding will occur.
  - 5. Follow guidelines outlined in the adhesive's Product Data Sheet.
  - 6. Read the adhesive's Material Safety Data Sheet (MSDS) prior to using the adhesive.
- E. Seaming:
  - 1. Weld overlapping sheets together using hot air. Minimum weld width is 1-1/2 inches.
  - 2. Check field welded seams for continuity and integrity and repair all imperfections by the end of each work day.
- F. Membrane Termination/Securement: All membrane terminations shall be completed in accordance with the membrane manufacturer's requirements.
  - 1. Provide securement at all membrane terminations at the perimeter of each roof level, roof section, curb flashing, skylight, expansion joint, interior wall, penthouse, and other similar condition.
  - 2. Provide securement at any angle change where the slope or combined slopes exceeds two inches in one horizontal foot.
  - 3. Ensure correct peel stop requirements are met attaching membrane with augers on the full perimeter.
- G. Flashings: Complete all flashings and terminations as indicated on the drawings and in accordance with the membrane manufacturer's requirements.
  - 1. Provide securement at all membrane terminations at the perimeter of each roof level, roof section, curb flashing, skylight, expansion joint, interior wall, penthouse, and other similar condition.
    - a. Do not apply flashing over existing thru-wall flashings or weep holes.
    - b. Secure flashing on a vertical surface before the seam between the flashing and the main

roof sheet is completed.

- c. Extend flashing membrane a minimum of 6 inches (152 mm) onto the main roof sheet beyond the mechanical securement.
- d. Use care to ensure that the flashing does not bridge locations where there is a change in direction (e.g. where the parapet meets the roof deck).
- 2. Penetrations:
  - a. Flash all pipes, supports, soil stacks, cold vents, and other penetrations passing through the roofing membrane as indicated on the Drawings and in accordance with the membrane manufacturer's requirements.
  - b. Utilize custom prefabricated flashings supplied by the membrane manufacturer.
  - c. Existing Flashings: Remove when necessary to allow new flashing to terminate directly to the penetration.
- 3. Pipe Clusters and Unusual Shapes:
  - a. Clusters of pipes or other penetrations which cannot be sealed with prefabricated membrane flashings shall be sealed by surrounding them with a prefabricated vinyl-coated metal pitch pan and sealant supplied by the membrane manufacturer.
  - b. Vinyl-coated metal pitch pans shall be installed, flashed and filled with sealant in accordance with the membrane manufacturer's requirements.
  - c. Pitch pans shall not be used where prefabricated or field fabricated flashings are possible.

## H. Roof Drains:

- 1. Coordinate installation of roof drains and vents specified in Section 15146 Plumbing Specialties.
- 2. Remove existing flashing and asphalt at existing drains in preparation for sealant and membrane.
- 3. Provide a smooth clean surface on the mating surface between the clamping ring and the drain base.
- I. Edge Details:
  - 1. Provide edge details as indicated on the Drawings. Install in accordance with the membrane manufacturer's requirements.
  - 2. Join individual sections in accordance with the membrane manufacturer's requirements.
  - 3. Coordinate installation of metal flashing and counter flashing specified in Section 07620.
  - 4. Manufactured Roof Specialties: Coordinate installation of copings, counter flashing systems, gutters, downspouts, and roof expansion assemblies specified in Section 07710.
- J. Walkways:
  - 1. Install walkways in accordance with the membrane manufacturer's requirements.
  - 2. Provide walkways where indicated on the Drawings.
  - 3. Install walkway pads at roof hatches, access doors, rooftop ladders and all other traffic concentration points regardless of traffic frequency. Provided in areas receiving regular traffic to service rooftop units or where a passageway over the surface is required.
  - 4. Do not install walkways over flashings or field seams until manufacturer's warranty inspection has been completed.

- K. Water cut-offs:
  - 1. Provide water cut-offs on a daily basis at the completion of work and at the onset of inclement weather.
  - 2. Provide water cut-offs to ensure that water does not flow beneath the completed sections of the new roofing system.
  - 3. Remove water cut-offs prior to the resumption of work.
  - 4. The integrity of the water cut-off is the sole responsibility of the roofing contractor.
  - 5. Any membrane contaminated by the cut-off material shall be cleaned or removed.

## 4. FIELD QUALITY CONTROL

A. The membrane manufacturer's representative shall provide a comprehensive final inspection after completion of the roof system. All application errors shall be addressed and final punch list completed.

## 5. PROTECTION

- A. Protect installed roofing products from construction operations until completion of project.
- B. Where traffic is anticipated over completed roofing membrane, protect from damage using durable materials that are compatible with membrane.
- C. Repair or replace damaged products after work is completed.

## END OF SECTION



119 W. Van Buren Ave. Ste. 101 Harlingen, TX 78550 Off: (956) 230-3435 Fax: (956) 720-0830 www.ethoseng.net

November 5, 2018 Cameron Appraisal District New Building Addition and Renovation

# ADDENDUM NO. 2

# A. PURPOSE AND INTENT

This addendum is issued for the purpose of modifying the plans and specifications for the project referenced above.

This addendum shall become part of the contract and all contractors shall be bound by its content. All aspects of the specifications and drawings not covered herein shall remain the same. The General Conditions and the Special Conditions of the specifications shall govern all parts of the work and apply in full force to this addendum.

# B. SCOPE

# I. Drawings:

- 1) Sheet R-E3.1:
  - a) Revised Existing Building Lighting Plan. See attached sheet R-E3.1a.
- 2) Sheet R-E4.1:
  - a) Revised Existing Building Lighting Plan. See attached sheet R-E4.1a.





