



1801 South 2nd Street, Ste. 330 McAllen, TX 78503

## Addendum No. 6

DATE: Friday, March 15, 2019

PROJECT: Edinburg Consolidated Independent School District  
Freddy Gonzalez Elementary Gymnasium Improvements

PROJECT NO: 1611801

LOCATION: McAllen, Texas


FROM: Laura N. Warren, The Warren Group Architects, Inc.


The following revisions and clarifications shall be considered part of the record contract documents dated February 15, 2019 for the above referenced project and included in the contract amount. All general notes and specifications shall apply to this addendum. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

As requested by Owner, the following scope adjustments have been made. Please adjust bids with the following noted changes:

- Item No. 1: **DBR clarification to RFI: Location of existing panels is unknown, and most likely in the building attached to the gym.**
- Item No. 2: **DBR clarification to RFI: Replacement of disconnects is shown on one-line diagram. Refer Construction Documents Sheet EPD2.11 and EP2.11 dated 02/15/2019.**
- Item No. 3: **DBR clarification to substitution: EST iO Series Fire Alarm panel has not been approved as a substitution to Kidde ESD Series Fire Alarm Panel.**

ISSUED BY:

  
Laura N. Warren, AIA/Principal  
The Warren Group Architects, Inc.



---

Attachments: None

**Distribution:**

Robert Estrada, District Architect  
Jacqueline W. Kingan, ECISD Senior Buyer  
Bidding Vendors  
File